



Undisturbed, inorganic mat'l in front and beneath wall.

NOTES:

1. Wall height over 1.5m to be designed by an Engineer.
2. Mortar shall be composed of one part portland cement and two parts sand.
3. Individual stones shall have a thickness not less than 100mm and a width not less than 1.5 times the thickness. Stones shall increase in thickness from the top to the bottom of the wall.
4. Backfill to be clean, free draining, granular material approved by the Engineer.



MUNICIPALITY OF CENTRAL SAANICH

TITLE:

ROCK RETAINING WALL

STD.DWG.No.

517

Approved;

Date; JUNE 1986

Scale; N.T.S.

Rev.